

LAMPIRAN

Konsep Kinerja Visual

Perhitungan kebutuhan lampu pada ruang baca perpustakaan remaja dan dewasa

Ukuran ruang baca memiliki kisaran ukuran :

- Panjang : 16,2 m
- Lebar : 10 m
- Tinggi : 2,5 m
- Luas : 162 m²
- volume : 405 m³

✚ Menghitung indeks ruang (K) untuk mencari UF (Utilization Factor)

$$K = \frac{P \times L}{T(P+L)}$$

$$K = \frac{16,2 \times 10}{2,5(16,2+10)}$$

$$= 2,4$$

cd/1000lm γ	0°				30°				60°				90°				room index k		
	0°	30°	60°	90°	0°	30°	60°	90°	0°	30°	60°	90°	0°	30°	60°	90°			
0	270																		
5	271																		
10	281																		
15	288																		
20	284																		
25	267																		
30	242																		
35	213																		
40	179																		
45	138																		
50	84																		
55	23																		
60	9																		
65	7																		
70	5																		
75	3																		
80	2																		
85	2																		

UF

✚ Menghitung DF (Design Factor)

$$DF = UF \times MF (90\%)$$

$$DF = 0,44 \times 0,9 = \mathbf{0,396}$$

✚ Kebutuhan iluminasi untuk kegiatan-kegiatan tertentu:

- **Penglihatan biasa** = **100 lux**
- Kerja kasar dengan detail besar = 200 lux
- Kerja umum dengan detail wajar = 400 lux
- Kerja cukup keras dengan detail kecil = 600 lux
- Kerja keras, lama, detail kecil
(merakit barang halus, menjahit dengan tangan) = 900 lux
- Kerja sangat keras, lama, detail sangat kecil
(memotongbatumulia, tisikhalus) = 1.300 – 2.000 lux
- Kerja luar biasa keras, detail sangat kecil
(merakit arloji, membuat instrumen) = 2.000 – 3.000 lux

Berdasarkan data yang terdapat di atas maka ruang baca membutuhkan sekitar

100 lux

$$E = \Phi / A$$

$$100 \text{ lux} = \Phi / 160 \text{ m}^2$$

$$\Phi = 100 \text{ lux} \times 160 \text{ m}^2$$

$$\Phi = 16.000 \text{ lm}$$

Dimana :

Φ = total arus cahaya (lm)

E = Iluminasi (lux)

A = Luas Area (m²)

Lampu yang digunakan Philips TL-D Standard colours Linear fluorescent tube 30 W, G13, Cool daylight (1825 lm)



Sumber : www.lightbulbmarket.com

Technical specifications

- Color rendering index (CRI): 75
- Dimmable: No
- Fitting/Cap: G13
- Lifetime: 13000 hour(s)
- Light effect: Cool daylight
- Light output: 1825 lumen
- Shape: Linear fluorescent tube
- Wattage: 30 W

$$\begin{aligned} \text{Perhitungan Lampu} &= \Phi / \text{ arus cahaya perlampu} \\ &= 16.000 / 1825 \text{ lm} \\ &= 8.76 \text{ titik lampu (pembulatan ke atas)} \\ &= 9 \text{ titik lampu} \end{aligned}$$

Jadi, titik lampu yang dibutuhkan untuk menerangi ruang baca adalah 9 lampu

Konsep Kinerja Termal.

- Luas seluruh bangunan perpustakaan ini adalah :

8.075,67 m²

- Luas ruang yang tidak di beri AC

Ruang loading dock, gudang, genset, toilet, ruang AHU dan Ruang ME,
ruang baca outdoor, ruang kontrol

$$27,5 \text{ m}^2 + 22 \text{ m}^2 + 27,5 \text{ m}^2 + 165 \text{ m}^2 + 55 \text{ m}^2 + 22 \text{ m}^2 + 195 \text{ m}^2 + 11 \text{ m}^2 \\ = 525 \text{ m}^2$$

- Luas bangunan yang di beri AC :

$$8.075,67 \text{ m}^2 - 525 \text{ m}^2 = 7.550,67 \text{ m}^2$$

Perhitungan beban AC :

Luas area x cooling load x 10/6 x 1,14

$$8.075,67 \text{ m}^2 \times 202 \times 10/6 \times 1,14$$

$$3.099.442,15 \text{ W} \rightarrow \mathbf{3.099,44 \text{ Kw}}$$

Perhitungan airflow

16 L/s x Luas area

$$16 \text{ L/s} \times 8.075,67 \text{ m}^2$$

$$\mathbf{129.210,72 \text{ L/s m}^2}$$

Berdasarkan perhitungan cooling load maka didapatkan system pendingin berupa


:

1. Chiller Water Set (CWS) water cooled

→ Total beban AC: **3.099,44 Kw**

CWS (water cooled)

This unit is normally installed within a plant room. The areas shown are based on duplex units.



Cooling kW(R)	A	B	C	D	area m ²	weight kg
100 to 250	6.7	4.5	2.8	2.4	30	2000
250 to 500	7.3	4.8	3.0	2.8	35	4000
500 to 750	7.7	5.2	3.2	3.2	40	5000
750 to 1000	8.2	5.5	3.2	3.6	45	7000
1000 to 1250	8.6	5.7	3.4	4.1	49	8000
1250 to 1500	8.8	5.9	3.6	4.4	52	9500
1500 to 1750	9.2	6.1	3.6	4.4	56	11000
1750 to 2000	9.4	6.3	3.8	4.4	59	13000
2000 to 3000	9.5	6.3	4.0	4.4	60	19000

For > 3000 kW(R) pro rata based on 3000 kW unit

3.099,44 Kw / 1000 kw = 3,09 jadi membutuhkan 3 unit CWS

2. Cooling Tower

→ Total beban AC : **3.099,44 Kw**

5.5 Cooling tower

Cooling towers of the 'induced draft' and 'forced draft' type are fully weather-proofed and best located in the open, but may be mounted behind an 'open mesh' site screen, which provides no restriction to the unit's air supply and discharge.

The 'forced draft' type may be located inside the building, provided that it has an unrestricted air supply and an exhaust duct of 1 m² cross-section per 200 kW(R), discharging to outdoors.



Cooling kW(R)	A	B	C	D	area m ²	weight kg
	metres					
100 to 200	4.3	2.8	1.8	0.9	12	840
200 to 400	5.4	3.7	1.9	1.0	20	1750
400 to 600	6.5	4.3	1.9	1.0	28	2700
600 to 800	7.3	4.9	2.0	1.0	36	3600
800 to 1000	8.0	5.4	2.2	1.1	43	4400
1000 to 1200	8.8	5.8	2.3	1.3	50	5400
1200 to 1400	9.2	6.1	2.6	1.3	56	6200
1400 to 1600	9.7	6.4	2.8	1.4	62	7200
1600 to 1800	10.1	6.7	3.0	1.5	68	8000
1800 to 2000	10.6	7.0	3.0	1.5	74	8800
2000 to 2200	11.0	7.3	3.0	1.5	80	9800
2200 to 2400	11.3	7.6	3.1	1.6	86	10800
2400 to 2600	11.7	7.8	3.3	1.7	91	11800
2600 to 2800	11.9	8.0	3.3	1.7	95	12400
2800 to 3000	12.2	8.1	3.3	1.7	99	13200

3.099,44 Kw / 1000 kw = 3,09 jadi membutuhkan 3 unit cooling tower


3. Auxiliaries (with all AHUs localized)

→ Total beban AC: 3.099,44 Kw

5.9 Auxiliaries

Auxiliaries cover all those minor items necessary for the effective operation of a central plant system. The plant room space shown includes return air fans, shafts, ductwork silencers, pipework and cabling, control centre, maintenance walkways, switchboards, panels, hatches, compressors, tanks, monitors, and pumps as appropriate.

(A) represents a central A/C system with all AHUs centralised.
 (B) represents a central A/C system with all AHUs localised.
 (C) represents any central heating system.



Cooling load kW(R)	(A) Auxiliaries		(B) Auxiliaries	
	area (m ²)	height (m)	area (m ²)	height (m)
150 to 200	48	4.7	16	2.7
201 to 250	52	4.8	17	2.8
251 to 300	55	4.9	18	2.9
300 to 350	60	5.0	20	3.0
351 to 400	65	5.0	22	3.0
401 to 450	70	5.2	23	3.2
451 to 500	74	5.2	25	3.2
501 to 600	84	5.4	28	3.4
601 to 700	92	5.4	31	3.4
701 to 800	102	5.6	34	3.6
801 to 900	110	5.6	37	3.6
901 to 1000	120	5.8	40	3.8
1001 to 1100	128	5.8	43	3.8
1101 to 1200	138	6.0	46	4.0
1201 to 1300	148	6.0	49	4.0
1301 to 1400	156	6.0	52	4.0
1401 to 1500	165	6.0	55	4.0
1501 to 1700	184	6.0	61	4.0
1701 to 1900	202	6.0	67	4.0
1901 to 2100	220	6.0	73	4.0
2101 to 2300	238	6.0	79	4.0
2301 to 2500	256	6.0	85	4.0

Heating load kW	(C) Auxiliaries	
	area (m ²)	height (m)
150 to 750	15	3.0
751 to 1500	25	3.5
1501 to 3000	35	4.0


3.099,44 Kw / 1500 kw = 2,06 untuk cooling load membutuhkan 2 unit

3.099,44 Kw / 1500 kw = 2,06 untuk heating load membutuhkan 2 unit

4. Floor Mounted AHU

➤ Air flow : **129.210,72 L/s m2**

Floor mounted AHU
 The dimensions shown include an access corridor on three sides. Locate the fourth side adjacent to an outside air intake.



Airflow L/s	A	B	C	D	area m ²	weight kg
	metres					
900 to 1200	3.1	2.8	2.6	0.7	9	750
1200 to 1800	3.4	2.8	2.6	0.7	10	1200
1800 to 2500	3.6	3.4	2.6	0.9	12	1500
2500 to 3200	3.7	4.0	2.6	1.0	15	1800
3200 to 4000	3.9	4.8	2.6	1.2	19	2100
4000 to 5000	4.2	5.0	2.6	1.3	21	2500
5000 to 6400	4.5	6.2	2.6	1.6	28	2900
6400 to 8200	4.8	6.2	2.6	1.6	30	3350
8200 to 9900	5.4	6.2	2.8	1.6	34	3700
9900 to 11600	5.6	6.2	3.1	1.6	35	4000
11600 to 14000	6.0	6.2	3.6	1.6	38	4400

For > 14000 L/s - pro rata based on 14000 L/s unit values

129.210,72 / 14000 = 9,22

Cara menentukan PK dalam ruangan

- Volume ruang baca remaja dan dewasa = 16,2 m x 10 m x 2,5 m = 405 m³
- Volume/3 x 500 = 405 /3 x 500 = 67.500 BTU/h

Macam macam AC:

- AC ½ PK = ± 5.000 BTU/h

- AC ¾ PK = ± 7.000 BTU/h
- AC 1 PK = ± 9.000 BTU/h
- AC 1½ PK = ± 12.000 BTU/h
- AC 2 PK = ± 18.000 BTU/h

Diambil menggunakan AC 1 PK maka $67.500 : 18.000 = 3,75$ dibulatkan menjadi 4 sehingga menggunakan 4 buah AC dengan ukuran 2 PK.

Lampiran Hasil Cek Plagiasi

FORMULIR SCAN ANTI PLAGIARISME

Nama : Martin Agus A.

Alamat email : Martin-chag3@yahoo.com

Fak. / Prodi : Arsitek & Desain NIM : 10.11.0027

berupa (TESIS, TUGAS AKHIR, SKRIPSI, SUMMARY, LAPORAN KERJA PRAKTEK)

dengan judul : Perputakaan Multimedia di Kota Semarang

Petugas,  2,7 Semarang, 14 April 2016
yang menyerahkan,
Martin A.

NB. Laporan hasil scan terlampir untuk Yang bersangkutan

703 matches from 52 sources, of which 43 are online sources.

PlagLevel: 2.7%/78.1%

- [0] (570 matches, 0.0%/78.1%) from your PlagScan document "10.11.0027 Martin.pdf" dated 2016-04-13
- [1] (10 matches, 0.5%) from your PlagScan document "10.11.0066 ryan.pdf" dated 2016-03-30
- [2] (5 matches, 0.4%/0.6%) from <https://fidansafira.wordpress.com/2014/10/02/jenis-jenis-perpustakaan/>
- [3] (6 matches, 0.5%) from your PlagScan document "12.11.0004 Angela C.docx" dated 2016-04-13
- [4] (6 matches, 0.4%) from your PlagScan document "12.11.0002 ...ia Budiyanto.docx" dated 2016-04-12
- [5] (6 matches, 0.4%) from your PlagScan document "12.11.0090 Ardian.pdf" dated 2016-04-14
- [6] (5 matches, 0.4%) from www.slideshare.net/perencanakota/rtrw-kota-semarang
(+ 3 documents with identical matches)
- [10] (9 matches, 0.4%) from <https://www.enjang.com/96-istilah-bidang-perpustakaan/>
- [11] (4 matches, 0.3%) from pamboedifiles.blogspot.com/2013/05/peta-pembagian-bwk-kota-semarang.html
- [12] (3 matches, 0.3%) from [library.umn.ac.id/umnlibrary/umnlibrary/content/Discussion Rooms](http://library.umn.ac.id/umnlibrary/umnlibrary/content/Discussion%20Rooms)
- [13] (3 matches, 0.3%) from www.necshopkpop.com/2011/03/isyaran-audiovisual-dan-multimedia-di.html
- [14] (7 matches, 0.2%) from your PlagScan document "10.11.0049 Aswin.docx" dated 2016-03-10
- [15] (4 matches, 0.3%) from <https://ml.scribd.com/doc/123117334/perda-14>
- [16] (5 matches, 0.2%) from your PlagScan document "08.11.0105 Wirandha.pdf" dated 2016-04-13
- [17] (3 matches, 0.2%) from ejournal-st.undip.ac.id/index.php/jpgs/article/download/3577/3490
- [18] (2 matches, 0.2%) from rahmisuke.blogspot.com/2011/09/koleksi-audiovisual-multimedia-dalam.html
- [19] (1 matches, 0.0%/0.3%) from dokumen.tips/documents/laporan-lan.html
- [20] (1 matches, 0.0%/0.2%) from www.facebook.com/PerpustakaanRadenAjengKartini
(+ 4 documents with identical matches)
- [25] (3 matches, 0.2%) from <https://id.scribd.com/doc/117398535/7573...-No-14-Tahun-2011-Tlg-RTRW-I>
- [26] (2 matches, 0.1%) from your PlagScan document "12.11.0041 Esther Agustine.docx" dated 2016-04-
- [27] (1 matches, 0.1%) from <https://ml.scribd.com/doc/46167484/Siste...am-Bangunan-Studi-Kasus-Mal-A>
- [28] (1 matches, 0.1%) from <https://id-id.facebook.com/tpbo14/posts/580223622046048>
- [29] (1 matches, 0.1%) from <https://1301313y.wordpress.com/2009/02/0...arsitektur-modempostmodern/>
(+ 4 documents with identical matches)
- [34] (2 matches, 0.1%) from <https://id.scribd.com/doc/269845688/Peraturan-Daerah-Semarang>
- [35] (1 matches, 0.1%) from arsiteklopedia.blogspot.com/2013/05/antara-arsitektur-modern-dan-post-mo
(+ 4 documents with identical matches)
- [40] (2 matches, 0.1%) from <https://ml.scribd.com/doc/195047414/LP3A-Repaired>
- [41] (1 matches, 0.1%) from iwan-arsitekidal.blogspot.com/2011/07/arsitektur-modern_8359.html
(+ 8 documents with identical matches)
- [50] (2 matches, 0.1%) from <https://blogbnm.wordpress.com/2014/03/22/menyusun-program-arsitektur/>
- [51] (2 matches, 0.1%) from your PlagScan document "12.11.0022 David Rickwan.docx" dated 2016-04-1

Settings

- Data policy: Compare with web sources, Check against my documents, Share with my organization,
- Participate in PlagScan database
- Sensitivity: Low
- Bibliography: Bibliography excluded
- Citation detection: Reduce PlagLevel
- Whitelist: --